



24-2509
Impact Resistant Security Film
August 29 2024

****Bid Due Date has been extended until Thursday September 12, 2024, at 10:00 A.M.** See below for updated Scope and Bid Form****

Addendum #1:
Questions

1. Section C pages 1-56 scope of work, It doesn't mention Impact Protection Adhesive (IPA) that holds the film to the frame, this is necessary according to 3M and other film companies. Does it need to be listed under materials?
Answer: If the product you propose requires adhesive then it needs to be included in material cost of proposal.
2. Are you requesting that the film is wet glazed/caulked post film installation?
Answer: If applicable to the material you're proposing then it needs to be included in material cost.
3. On page 50 of the RFP there are four windows stated at 31x360, is this a typo? Was it meant to be 31x36?
Answer: Yes, it should have been listed as 31x36.
4. Are there existing films to be removed?
Answer: No
5. Is this project subject to prevailing wage requirements?
Answer: No this is not subject to prevailing wage requirements.
6. Should the installation take place during afterhours or regular hours?
Answer: During school hours.
7. Is a performance bond required?
Answer: No
8. Could you provide the previous bid tabulation for reference?
Answer: There is no previous bid tabulation. The previous bid was pulled down prior to receiving any bids.
9. Do we need to include a hard completion date in the contract?
Answer: No, a hard completion date is not required for bid.
10. The bid form lists "Saluda Trail Middle/Exterior" twice; could you please confirm this?
Answer: The 2nd line should have stated "Saluda Trail Middle/Interior". A revised bid form is attached to the addendum.
11. Does the 10% SMBE Utilization Plan apply to this bid?
Answer: Award will go to the lowest responsive bidder.
12. Bid does not mention a wet glaze attachment system or impact protection adhesive caulking. These are typical in combination with security film and are required to keep

the warranty in most situation. Are we to price it or is not being called out for a specific reason?**Answer: See Question 2**

19. Mobilizations/Install Deadlines? Is there a timeframe that the district needs all the schools to be done by? I see on page 10: "13 TIME OF COMPLETION" Date of delivery shall be a consideration factor in the awarding process. "Shall we just put next to each pricing row on "Appendix I Bid Form" the date that we plan to finish the install by? Are all the 28 schools ready for install/ so we could install as fast as we'd like? **Answer: All schools are ready, and we would prefer a quick turnaround. Work needs to be completed during school hours.**
20. Working Hours Do our installers need to adhere to a specific timeframe of day or days of week for install? **Answer: Monday through Friday 8:00am through 4:00pm**
21. Taxes South Carolina Sales Taxes doesn't apply for this bid and we don't need to include or show as a separate entity in the bid, correct? **Answer: We are not tax exempt, but you do not need to include taxes for bidding purposes.**
22. What manufacturer is making the claim of 14 mil products meeting the classification? I am not personally aware of a 14 mil polyester film that offers any type of bullet resistance protection. **Answer: It needs to be "impact resistant" not bullet proof.**
23. Is this requirement calling for multiple layers of 14 mil or greater security film in order to be capable of reaching one of the BR classifications listed above? UL and JIJ levels of bullet resistant film/laminate do not exist without layering film. **Answer See updated scope**
- a. If so, what millimeter thickness is desired and how many layers of film? **Answer: See updated scope**
24. Is the school looking for a true bullet resistant solution that that covers every UL and NIJ Bullet resistant level (10)? Or are you looking for a certain level of protection?
- a. If so, can you please define the desired level of BR protection? **Answer: See updated scope**
25. Is the existing glass that will be receiving the security film in steel or aluminum framing? **Answer: Varies across sites.**
26. Is any of the glass annealed (untreated), tempered, or double paned? **Answer: This can vary across sites.**
27. Is there any existing film in place on the glass in question such as tint or other legacy anti-intrusion film? **Answer: There could be some windows with graphics/branding.**

Rock Hill, SC 29730	School Road Rock Hill, SC 29732	
Dutchman Creek Middle School 4757 Mount Gallant Road Rock Hill, SC 29732	Sylvia Circle Family Literacy Center 929 Sylvia Circle Rock Hill, SC 29730	
Ebenezer Avenue Elementary 242 Ebenezer Avenue Rock Hill, SC 29730	Rawlinson Road Middle School 2631 W. Main Street Rock Hill, SC 29732	
Ebinport Elementary School 2142 India Hook Road Rock Hill, SC 29732	Richmond Drive Elementary School 1162 Richmond Drive Rock Hill, SC 29732	
Flexible Learning Center 1234 Flint Street Ext. Rock Hill, SC 29730	Rock Hill High School 320 W. Springdale Road Rock Hill, SC 29730	
Independence Elementary School 132 W. Springdale Road Rock Hill, SC 29730	Saluda Trail Middle School 2300 Saluda Road Rock Hill, SC 29730	
India Hook Elementary School 2068 Yukon Drive Rock Hill, SC 29732	South Pointe High School 801 Neely Road Rock Hill, SC 29730	
Lesslie Elementary School 250 Neely Store Road Rock Hill, SC 29730	Sullivan Middle School 1825 Eden Terrace Rock Hill, SC 29730	

Mount Gallant Elementary School 4664 Mount Gallant Road Rock Hill, SC29732	Sunset Park Elementary School 1036 Ogden Road Rock Hill, SC29730	
---	---	--

It is understood that the Contractor and its employees will act in the capacity of an independent Contractor. (b) (6) (i) (s)-2 re 1MT17td (b) (7) eme2e fMT17td (t) N3 (o) 5 (nt) 6 (

***SEE APPENDIX BID FORM 24

Mount Holly Elementary/Interior			
Mt. Gallant Elementary/Exterior			
Mt. Gallant Elementary/Interior			
Northside Elementary/Exterior			
Northside Elementary/Interior			
Northwestern High/Exterior			
Oakdale Elementary/Exterior			
Oakdale Elementary/Interior			
Old Pointe Elementary/Exterior			
Old Pointe Elementary/Interior			

Rawlinson Road Middle/Exterior