

24-2510
Greenhouse at ATC
October 23 2024

Addendum #1:

1. Is the interior electrical to be included? Answer: ~~Yes~~ interior electrical cost should be included in your bid.
2. What is the power supply? Answer: ~~10~~/240 single phase
3. Are lights required? Is there a spec? Answer: ~~Yes~~ lights are required. We would like watertight pendant lights included (1 per 12')
4. Are we to supply fire extinguisher? Answer: ~~Yes~~ fire extinguisher should be supplied.
5. Are we to supply exit signs with remote head? Answer: ~~Yes~~ supply one exit sign per door.
6. On the concrete slab does greenhouse supplier need to provide base reactions for Rock Hill architect to design the foundation or is the greenhouse supplier providing a slab design with SC registered engineer? Answer: Please provide slab design with SC registered engineer.
7. Do doors require locksets with removable cores? Answer: Standard greenhouse doors that come with a basic lever lockset will be sufficient.
8. Is special door hardware or any other features needed? Answer: No, we are not requiring any special door hardware.
9. Is Irrigation required? all PVC, brass

r, punch tool, manual valves and anything else required for
on system.

